



2022 CALGREEN RESIDENTIAL MANDATORY MEASURES EFFECTIVE JANUARY 1, 2023

HCD SHL 615 (New 01/23)

See specific referenced sections for complete details on CALGreen mandatory requirements.

2022 CALGREEN CODE

SECTION	REQUIREMENTS
Division 4.3 – WATER EFFICIENCY AND CONSERVATION	
	Water conserving plumbing fixtures and fittings
4.303.1	<p>Plumbing fixtures and fittings shall comply with the following:</p> <ul style="list-style-type: none"> 4.303.1.1 – Water closets: ≤ 1.28 gal/flush. 4.303.1.2 – Wall mounted urinals: ≤ 0.125 gal/flush; all other urinals ≤ 0.5 gal/flush. 4.303.1.3.1 – Single showerheads: ≤ 1.8 gpm @ 80 psi. 4.303.1.3.2 – Multiple showerheads: combined flow rate of all showerheads controlled by a single valve shall not exceed 1.8 gpm @ 80 psi, or only 1 shower outlet is to be in operation at a time. 4.303.1.4.1 – Residential lavatory faucets: maximum flow rate ≤ 1.2 gpm @ 60 psi; minimum flow rate ≥ 0.8 gpm @ 20 psi. 4.303.1.4.2 – Lavatory faucets in common and public use areas of residential buildings: ≤ 0.5 gpm @ 60 psi. 4.303.1.4.3 – Metering faucets: ≤ 0.2 gallons per cycle. 4.303.1.4.4 – Kitchen faucets: ≤ 1.8 gpm @ 60 psi; temporary increase to 2.2 gpm allowed but shall default to 1.8 gpm.
	Standards for plumbing fixtures and fittings
4.303.2	Plumbing fixtures and fittings shall be installed in accordance with the California Plumbing Code, and shall meet applicable standards referenced in Table 1701.1 of the California Plumbing Code.
	Outdoor potable water use in landscape areas
4.304.1	New residential developments shall comply with a local water efficient landscape ordinance or the current California Department of Water Resources' Model Water Efficient Landscape Ordinance (MWELO), whichever is more stringent.
Division 4.4 – MATERIAL CONSERVATION & RESOURCE EFFICIENCY	
	Rodent proofing
4.406.1	Annular spaces around pipes, electric cables, conduits or other openings in sole/bottom plates at exterior walls shall be closed with cement mortar, concrete masonry or a similar method acceptable to the enforcing agency to prevent passage of rodents.

